

**GOVERNMENT OF ANDHRA PRADESH**  
**STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**

**From :**

The District Fire Officer  
Near Court, Indira Nagar,  
Balaji Colony, Tirupati,  
Andhra Pradesh-517501.

**To :**

The Secretary,  
Audisankara College of  
Engineering & Technology, Gudur,  
Tirupati District,  
Andhra Pradesh-524101

**Re.No.11769/Tirupati/RF0/2023 (MSB-ER Dated:17-03-2023).**

Sir,

Sub: FIRE & EMERGENCY DEPARTMENTS.R- Tirupati District-  
Issuance of Renewal of No Objection Certificate to the Existing Buildings of  
M/Audisankara College of Engineering & Technology, represented by Dr.  
Vanki Penchalaiah, Secretary & Correspondent, NH-16 Bypass Road, Gudur.  
Tirupati District-Regarding.

- Ref: 1. Occupancy NOC File No. 11769/Tirupati/RFO/2023, Dt:02.02.2023  
of District Fire Officer, Tirupati, Andhra Pradesh.
2. Application of M/s Audisankara College of Engineering & Technology,  
Represented by Dr. Vanki Penchalaiah, NH-16, Bypass Road, Gudur,  
Tirupati District.

\*\*\*

1). The Management of M/s Audisankara College of Engineering & Technology, Represented by Dr Vanki Penchalaiah, Secretary & Correspondent, NH-16 Bypass Road, Gudur, Tirupati District, has requested to issue Renewal of No Objection Certificate by duly remitting the Renewal Fee towards Fire Precautionary Fee vide reference 2nd cited.

2). The No Objection Certificate for Occupancy was issued vide referencelst cited to the Existing Building of M/s Audisankara College of Engineering & Technology, represented by Dr. Vanki Penchalaiah, Secretary & Correspondent, NH-16 Bypass Road, Gudur, Tirupati District with Ground 04 Upper Floors with Built up area 57728 Sq. Mtrs.. with a Height of 15.80 Mtrs., for Educational Occupancy,

3) The management has submitted the Self-Certification report and stated that the furnished information is correct and it is noticed at any time that the information provided is false, they understand that Renewal NOC deemed may be cancelled by the concerned authority.

4) In view of the above and taking into consideration of the larger public interest and in the context of the COVID-19 pandemic across the country and also based on the Self-Certification submitted by the management, the Renewal of No Objection Certificate is issued to the Existing Buildings. Audisankara College of Engineering & Technology, NH-16 Bypass Road, Gudur, Tirupati District with Ground+04 Upper Floors with Built-up area of 57728 Sq. Mtrs., with a Height of 15.80 Mtrs., for Educational Occupancy.

(contd.....2p)

**Details of Buildings**

Sl.No	Building	Area in Sq. Mts	Occupancy (Educational / Hostel / Dormitory Occupancy)
1	Building A	16872	Educational Occupancy
2	Building B	3672	Educational Occupancy
3	Building C	5250	Educational Occupancy
4	Building D	6188	Educational Occupancy
5	Building E	4303	Educational Occupancy
6	Building F	3580	Educational Occupancy
7	Building G	6366	Educational Occupancy
8	Building H	3038	Educational Occupancy
9	Building AA	6188	Educational Occupancy
10	Building AB	2269	Educational Occupancy

5) It is suggested to the Management for providing the following Fire Safety Measures keeping in view of Practicality, Maintenance and Resilience.

Sl. No.	Fire Fighting Equipment	Prescribed	Available with Nos.	Deficit
1	Fire Extinguishers	ABC/CO2 type	136 Nos.	Nil
2	Underground parking/ Cellar/ Basement	Temperature Sensors connected to " Hooter " and that can be give alerts through Cell phone instead of Sprinklers.	Not Applicable	
3	Manual Call Point System	One Number per Floor	09 Nos.	Nil
4	Under Ground Static Water Tank (or) Terrace Water Tank.	5,000 Ltrs. (Minimum)	50,000 Ltrs.	Nil
5	2 HP (Pump + Electrical Motors connected) @ one per Floor connected to Normal Plumbing System instead of Down Comer /Special Pipes.	One per each Floor (Total 05 Floors)	09 Nos.	Nil
6	5 HP (Mobile Pump + Petrol Engine on wheels on nested to Ground Floor Sump).	One Number	04 Nos.	Nil



**6).Electrical Safety System:**

(i) Miniature Circuit Breakers, MCB's.	:	Yes, Provided
(ii) No Overloading of Power Sockets.	:	Yes, Ensured
(iii) Whether, 10 years old wiring to be changed specially wherever A/c is there ?	:	Yes, Ensured
(iv) LED Lights in Closed Rooms, Corridors, Staircases connected to Inverter (Battery).	:	Yes, Connected
(v) Grounding/Earthing is provided.	:	Yes, Provided
(vi) Lightening Conductor is provided.	:	Not Applicale
(vii) The above shall be certified by authorized Electrical Contractor/Supervisor.	:	Not Applicale

**7) Fire Safety Suggestions:**

Sl. No.	As Builder	As Occupant	As Security Personnel
1	All the Fire protection arrangements shall be maintained in good working at all time.	The Escape/Exit roots shall not be kept Locked/ Blocked or Encroached.	All the occupants must be trained the correct method of operation of the fire Fighting System installed.
2	Any loss of life or property due to non-functioning of Fire Safety Measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the Fire Safety Equipment during Emergency.	Mock Drills should be conducted one in 03 months for initial two years. Thereafter, once in every 06 Months.
3	Additional/Alteration, if any in the building may be verified by Building Authority	Mock Drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.	All Security Personnel shall be trained to operate the Fire Safety Equipment during Emergency.
4	This Annual Periodical Renewal Fire Certificate is only from Fire Safety Point of View	Raise the alarm if the Fire cannot be controlled Evacuate the area completely at once with nearest Safe Exit	Attack the Fire using available Fire Equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing Doors and Windows.

8). This Renewal of No Objection Certificate is valid for a period of Five (05) years from the date of issue of this letter subject to the compliance of above Fire and Electrical Safety Measures. The Owner / Occupier/ Builder/ Management concerned of the Building shall submit Self Declaration / Certification with regard to working condition of above Fire Safety System every year in the prescribed format and submit/upload the photographs of the Mock Drills conducted in the premises. It is the responsibility of the Builder to maintain the Fire Safety Equipment in good working condition at all times and apply for next Periodical Renewal of No Objection Certificate, duly remitting the User Charges vide G.O.Ms.No.90, Home (Prisons & Fire Services) Department.

Yours,  
  
**District Officer**  
**Tirupati District,**  
 Fire & Emergency Services,  
 Tirupati, Andhra Pradesh.  


Copy to the Management, M/s Audisankara College of Engineering & Technology, represented by Dr.Vanki Penchalaiah, Secretary & Correspondent, NH-16 Bypass Road, Gudur, Tirupati District.  
 Copy to Regional Fire Officer, S.R, Vijayawada for information  
 Copy to Asst. District Fire Officer, Tirupati.

**Note: In case of any emergency call to 101 or State Fire Control Room-0866 2570101.**